

VERIFICATION OF COMPLIANCE

No.: LVD GZES2110029217HS

Applicant: Guangdong Carrier Heating, Ventilation & Air Conditioning Company Limited
1, Helangsha Village, Shengli Industrial Zone, Lishui Town, Nanhai, Foshan, Guangdong 528244, China

Manufacturer: Same as applicant

Product Name: Heat Pump

Product Description: Heat Pump

Model No.: CLS-F30HW/ZR1B, CLS-F65HW/ZR1B, CLS-F130HW/ZR1B

Trade Mark: **GCHV**

Rating: 380 V – 415 V 3N~; 50 Hz;
CLS-F30HW/ZR1B: 15000 W; 30,0 A
CLS-F65HW/ZR1B: 28000 W; 51,0 A
CLS-F130HW/ZR1B: 60000 W; 106,0 A

Protection against Electric Shock: Class I

Degree of Protection: Outdoor unit: IPX4

Additional Information: Refrigerant: R410A

Sufficient samples of the product have been tested and found to be in conformity with

Test Standard: EN 60335-2-40: 2003 + A11 + A12 + A1+ A2 + A13
EN 60335-1: 2012 + A11 + A13 + A1 + A14 + A2
EN 62233: 2008

as shown in the

Test Report Number(s): GZES211002921701

This Verification of Compliance has been granted to the applicant based on the results of tests, performed by Laboratory of SGS-CSTC Standards Technical Services Co., Ltd. on sample of the above-mentioned product in accordance with the provisions of the relevant harmonized standards under the Low Voltage Directive 2014/35/EU. The CE marking as shown below can be affixed, under the responsibility of the manufacturer, after completion of an EC Declaration of Conformity and compliance with all relevant EC Directives. The affixing of the CE marking presumes in addition that the conditions in annexes III and IV of the Directive are fulfilled.


David Guo
Senior Technical Manager
SGS-CSTC



2021-10-26

Copyright of this verification is owned by SGS-CSTC Standards Technical Services Co., Ltd. and may not be reproduced other than in full and with the prior approval of the General Manager. This verification is subjected to the governance of the General Conditions of Services, printed overleaf.

Member of SGS Group (Société Générale de Surveillance)