



Product Service

# Attestation of Conformity

No. N8A 074489 0059 Rev. 01

**Holder of Certificate:** **Yingli Energy (China) Co., Ltd.**  
3399 Chaoyang North Street  
071051 Baoding  
PEOPLE'S REPUBLIC OF CHINA

**Product:** **Crystalline Silicon Terrestrial Photovoltaic (PV) Modules**  
**Mono-crystalline Silicon Photovoltaic (PV) Modules**

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for testing and certification. For details see: [www.tuvsud.com/ps-cert](http://www.tuvsud.com/ps-cert)

**Test report no.:** 882162003502

**Date,** 2020-06-02

  
( Xinlian LUO )

Page 1 of 3

After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.



Product Service

# Attestation of Conformity

No. N8A 074489 0059 Rev. 01

## Model(s):

All electrical data is shown as relative to this test conditions:  
 Front side irradiance 1000W/m<sup>2</sup>  
 Backside irradiance 135W/m<sup>2</sup>  
 25 °C, AM 1.5

### 6" mono C-Si (N type) bifacial modules:

YLxxxCG2536F-1(xxx=375-445, in steps of 5, 72 cells)  
 YLxxxCG2536L-1(xxx=375-445, in steps of 5, 72 cells)  
 YLxxxCG2530F-1(xxx=310-370, in steps of 5, 60 cells)  
 YLxxxCG2530L-1(xxx=310-370, in steps of 5, 60 cells)

### 6" mono 1/2 cut C-Si (N type) bifacial modules:

YLxxxCG2536F-1 1/2(xxx=420-455, in steps of 5, 144 cells)  
 YLxxxCG2536L-1 1/2(xxx=420-455, in steps of 5, 144 cells)  
 YLxxxCG2530F-1 1/2(xxx=350-360, 370-375, in steps of 5, 120 cells)  
 YLxxxCG2530L-1 1/2(xxx=350-360, 370-375, in steps of 5, 120 cells)  
 xxx is standing for equivalent output power

All electrical data is shown as relative to standard conditions:  
 Front side irradiance 1000W/m<sup>2</sup>  
 25 °C, AM 1.5

### 6" mono C-Si (N type) facial modules:

YLxxxCG2536F-2(xxx=325-400, in steps of 5, 72 cells);  
 YLxxxCG2536L-2(xxx=325-400, in steps of 5, 72 cells);  
 YLxxxCG2530F-2(xxx=270-330, in steps of 5, 60 cells)  
 YLxxxCG2530L-2(xxx=270-330, in steps of 5, 60 cells)

### 6" mono C-Si (P type) facial modules:

YLxxxDG2536F-2(xxx=320-395, in steps of 5, 72 cells)  
 YLxxxDG2536L-2(xxx=320-395, in steps of 5, 72 cells)  
 YLxxxDG2530F-2(xxx=270-325, in steps of 5, 60 cells)  
 YLxxxDG2530L-2(xxx=270-325, in steps of 5, 60 cells)

### 6" mono 1/2 cut C-Si (N type) facial modules:

YLxxxCG2536F-2 1/2(xxx=340-410, in steps of 5, 144 cells)  
 YLxxxCG2536L-2 1/2(xxx=340-410, in steps of 5, 144 cells)  
 YLxxxCG2530F-2 1/2(xxx=280-340, in steps of 5, 120 cells)  
 YLxxxCG2530L-2 1/2(xxx=280-340, in steps of 5, 120 cells)

### 6" mono 1/2 cut C-Si (P type) facial modules:

YLxxxDG2536F-2 1/2(xxx=390-410, in steps of 5, 144 cells)  
 YLxxxDG2536L-2 1/2(xxx=390-410, in steps of 5, 144 cells)  
 YLxxxDG2530F-2 1/2(xxx=325-340, in steps of 5, 120 cells)  
 YLxxxDG2530L-2 1/2(xxx=325-340, in steps of 5, 120 cells)  
 YLxxxDF72 1/2(xxx=430-455, in steps of 5, 144 cells)  
 YLxxxDL72 1/2(xxx=430-455, in steps of 5, 144 cells)  
 YLxxxDF60 1/2(xxx=360-375, in steps of 5, 120 cells)  
 YLxxxDL60 1/2(xxx=360-375, in steps of 5, 120 cells)  
 xxx is standing for rated output power at STC



Product Service

# Attestation of Conformity

No. N8A 074489 0059 Rev. 01

## Parameters:

Safety Class: Class II

Max. System Voltage: 1500V DC

Fire Safety Class: Class A according to UL790

Construction: Framed or Frameless, with Junction box, cable and connector

## Tested according to:

EN IEC 61730-1:2018

EN IEC 61730-2:2018

EN IEC 61730-1:2018/AC:2018-06

EN IEC 61730-2:2018/AC:2018-06

Page 3 of 3

After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.